

<h1>Test Report</h1> <p>Issued by University of Salford (Acoustics Test Laboratory)  Date of Issue: 5<sup>th</sup> March 2026  Report Number: 07607/14</p>	
<p>Page 1 of 14</p>	
<p>APPROVED SIGNATORIES</p> <p>Claire Lomax [x]      Andy Moorhouse [ ]        Gary Phillips [ ]      Danny McCaul [ ]</p>	
<p><b>acoustic test &amp; calibration laboratory</b></p> <p>The University of Salford, Salford, Greater Manchester, M5 4WT, UK  <a href="http://www.acoustics.salford.ac.uk">http://www.acoustics.salford.ac.uk</a>  t 0161 295 3030/0161 295 3319 f 0161 295 4456 e c.lomax1@salford.ac.uk</p>	

## Determination of airborne noise from an appliance

**Measurements described in this test report comply with:-**  
**BS EN ISO 3744:2010 ‘Acoustics. Determination of sound power levels and sound energy levels of noise sources using sound pressure. Engineering methods for an essentially free field over a reflecting plane’**

COMPANY NAME & ADDRESS:	Chauvet UK POD 1 EVO Park Nottingham NG16 6NT
FOR ATTENTION OF:	Ben Virgo
UNIT UNDER TEST:	Lighting Unit, COLORado Solo Bar 6
DATE OF TEST:	28 <sup>th</sup> January 2025
TEST ENGINEER:	Sean Furlong
MEASUREMENT PURPOSE:	To determine airborne noise by measurements to the above standards.

*Results relate only to samples tested. Items tested are the samples supplied by the manufacturer, who was responsible for selecting at random from a standard production run.*

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 2 of 14

## 1.0 Description of Appliance Under Test

CATEGORY:	Lighting Unit
DESIGN CHARACTERISTICS:	Floor mounted
MANUFACTURER:	Chauvet
MODEL:	COLORado Solo Bar 6
TEST REF NUMBERS:	07607/14_1 & 2
SERIAL NUMBER:	030322790825000034
POWER:	Not Stated
POWER SOURCE:	UK Mains
SETTINGS: <i>*See Table 1.0 below for details of settings</i>	07607/14_1 “Ambient” 07607/14_2 “Auto”

*\* Table 1.0 – Manufacturer’s description of the different settings of the sample that were used to create the Test Configuration for each measurement.*

Explanation of Settings Used for Each Test	
Setting Name	Test Configuration
Ambient	Unit is in idle state, switched on and 0% Light output
Auto	All Effects Static, 100% Light output

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 3 of 14

## 2.0 Test Conditions

2.1 The following conditions were measured over duration of the test:-

	Measured Average Value
<b>TEST REF NUMBER:</b>	<b>07607/14_1 &amp; 2</b>
<b>SERIAL NO. / SAMPLE REF.</b>	030322790825000034
Atmospheric Pressure	98.412
Ambient Temperature	21.8
Ambient Relative Humidity	33.1

- 2.2 The test was carried out in the hemi-anechoic chamber at the University of Salford.
- 2.3 The unit under test was mounted directly on the floor, in the centre of the hemi-anechoic chamber.
- 2.4 Unit operation was controlled by the client from outside the chamber, after initial configuration directly at the unit. Measurements were taken immediately after each setting of the unit was set and confirmed by the client.
- 2.5 For measurement of the sound pressure level of the Reference Sound Source (RSS), the RSS was placed directly on the floor of the hemi-anechoic chamber at the same location as the unit under test as defined in BS EN ISO 3744: 2010.


# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 4 of 14



*Figure 1 – unit under test mounted in the hemi-anechoic chamber at the University of Salford.*

## **3 Acoustical Data**

### **3.1 Measurement method**

A direct measurement method was used as stated in BS EN ISO 3744: 2010.

### **3.2 Reference Sound Source**

The Laboratory reference sound source (RSS) type B&K 4204, serial number 1460189 was used on mains supply.

### **3.3 Microphone Array**

Ten laboratory free field, low noise microphones were used for the measurement, placed in fixed positions 1 to 10 on a hemispherical surface ( $d = 1.50$  m) with guidance from BS EN ISO 3744: 2010. The location of each measurement position is provided in Appendix 1 to this report.

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 5 of 14

## 3.4 Measured sound pressure levels of the unit

Each unit was run at the selected setting. Three measurements were made at each setting.

Mean sound pressure levels were measured over 30 seconds to give the measured sound pressure levels,  $L_{pi}$  at each measurement position in each third octave band. The sound power level was then calculated.

The background noise corrections  $K_1$ , environmental correction calculated from RSS levels  $K_2$ , measured sound pressure levels,  $L_{pi}$  at each measurement point, corrected sound pressure levels,  $L_{pf}$ , and the sound power level,  $L_w$  of the source in each third octave frequency band are given in Appendix 2 of this report. The measured time averaged sound pressure level of the RSS,  $L'_{p(RSS)}$ , at each microphone position is reported in Appendix 3 to this report.

## 3.5 Calculated sound power levels

The calculated A-Weighted sound power level,  $L_{WA}$  in dBA for each setting are given in table 3.1.

Table 3.1 –A-weighted noise emissions for each setting, averaged over 30 seconds and over 10 microphone positions.

Test Number	07607/14_1	07607/14_2
Setting	Ambient	Auto
A-weighted sound power level, $L_{WA}$ in dBA	38.5	38.7

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 6 of 14

## 3.6 Sound Pressure Level at 1 m from the source (not covered by BS EN 3744: 2010)

The A-weighted Sound Power Level can be used to calculate the A-weighted sound pressure level expected at different distances from the source in hemi-anechoic free field conditions\*.

The calculation of the sound pressure levels is based on the formulae in BS EN 3744: 2010 for a parallelepiped measurement surface (for a noise source measured, in this case, above a single reflective plane).

The calculations show that to estimate the average sound pressure level expected at a distance of 1 m from the surface of the unit, 13.5 dB should be subtracted from the sound power value. This would give A-weighted average sound pressure levels in table 3.2 for each unit setting at 1 m from the surface of the unit:-

Table 3.2 – Calculated A-weighted sound pressure level\* for each setting at 1 m from the unit surface

Test Number	07607/14_1	07607/14_2
Setting	Ambient	Auto
A-weighted sound pressure level, $L_p$ in dBA	25.0	25.2

*\*This calculation represents an estimate of the levels that would be obtained in hemi-anechoic free field conditions and should not be assumed to be valid for any specific building environments where the characteristics of the room should be accounted for.*

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 7 of 14

## Appendix 1 – Locations of measurement positions

### Defining measurement surface & Co-ordinates

Measurement distance, d

1.50 m

	x, mm	y, mm	z, mm
Microphone Position 1	-1485	0	225
Microphone Position 2	750	-1290	225
Microphone Position 3	750	1290	225
Microphone Position 4	-675	1155	675
Microphone Position 5	-675	-1155	675
Microphone Position 6	1335	0	675
Microphone Position 7	495	855	1125
Microphone Position 8	-990	0	1125
Microphone Position 9	495	-855	1125
Microphone Position 10	0	0	1500

Surface Area, m<sup>2</sup>

14.14 m<sup>2</sup>

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 8 of 14

## Appendix 2 – Measurements and calculations according to BS EN ISO 3744

The following tables include measurement details that provide in each third octave band, for each of the seven settings:-

- measured  $L_{pi}$ , averaged over 30 s, at each measurement position
- background noise corrections  $K_1$
- environmental correction  $K_2$ , calculated from RSS levels
- corrected sound pressure levels,  $L_{pf}$
- the sound power level,  $L_w$  of the source
- the A-weighted sound power level,  $L_{wA}$  of the source

! The levels at these frequencies are affected by background level and therefore levels quoted represent an upper limit for the sound pressure levels of the noise source.

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 9 of 14

MEASURED TIME AVERAGED SPL at 1.5 m, L'P - [07607/14_1 – "Ambient" Setting]											Mean L <sub>p</sub> over mic positions	$\Delta L_p$ [dB]	BG corr. K <sub>1</sub> , [dB]	Env corr. K <sub>2</sub> , [dB]	L <sub>p</sub> [dB]	Sound Power, L <sub>w</sub> [dB]	A- weighting corrections [dB]	Sound Power, L <sub>wA</sub> [dB]
Frequency [Hz]	Mic 1 [dB]	Mic 2 [dB]	Mic 3 [dB]	Mic 4 [dB]	Mic 5 [dB]	Mic 6 [dB]	Mic 7 [dB]	Mic 8 [dB]	Mic 9 [dB]	Mic 10 [dB]								
100	6.2	6.3	10.1	4.6	5.2	4.9	3.6	3.8	1.8	3.2	5.6	-0.1	1.30	-2.0	6.3	17.8	-19.1	-1.3
125	6.7	5.7	8.5	6.6	8.4	7.1	6.8	5.3	5.3	-1.7	6.5	1.5	1.30	1.5	3.7	15.2	-16.1	-0.9
160	6.4	6.2	8.7	5.7	7.4	6.9	6.3	3.8	4.2	-2.8	6.0	6.3	1.15	0.3	4.6	16.1	-13.4	2.7
200	13.7	13.5	16.0	13.4	15.0	13.0	15.1	10.4	12.2	3.8	13.4	19.9	0.00	-0.1	13.5	25.0	-10.9	14.1
250	12.5	9.7	12.7	11.3	13.0	9.4	9.8	7.2	7.3	3.8	10.4	18.5	0.00	1.1	9.3	20.8	-8.6	12.2
315	10.5	10.7	13.9	10.8	13.1	9.8	10.3	11.0	8.8	10.6	11.2	19.4	0.00	0.6	10.5	22.0	-6.6	15.4
400	13.4	13.2	16.6	14.0	14.5	13.5	13.6	13.2	13.3	11.2	13.8	23.3	0.00	0.5	13.3	24.8	-4.8	20.0
500	17.7	16.5	20.8	17.8	18.7	16.9	17.0	16.4	16.7	16.2	17.7	27.0	0.00	0.5	17.2	28.7	-3.2	25.5
630	23.0	20.5	25.3	21.3	22.6	19.3	19.9	19.9	18.9	18.5	21.4	30.5	0.00	0.6	20.8	32.3	-1.9	30.4
800	25.2	26.6	28.4	20.6	26.1	22.4	22.2	22.7	22.2	23.9	24.7	33.3	0.00	0.7	24.0	35.5	-0.8	34.7
1000	22.9	21.8	23.6	19.1	20.9	18.5	16.3	16.9	17.2	16.2	20.2	28.1	0.00	0.6	19.6	31.1	0	31.1
1250	18.1	17.0	14.1	14.7	14.8	14.7	12.9	12.8	12.4	11.6	14.8	22.1	0.00	0.5	14.2	25.7	0.6	26.3
1600	11.2	12.9	13.7	18.6	9.8	14.7	11.9	11.1	12.5	10.6	13.5	20.1	0.00	0.6	12.9	24.5	1	25.5
2000	13.7	10.5	12.0	14.1	8.9	10.9	13.5	10.5	9.9	7.6	11.6	17.3	0.00	0.9	10.7	22.2	1.2	23.4
2500	8.8	5.4	8.2	6.2	5.5	6.6	8.9	4.4	2.2	2.5	6.4	11.7	0.30	-1.4	7.5	19.0	1.3	20.3
3150	2.8	2.4	5.6	3.9	3.9	3.4	3.8	3.5	1.2	2.0	3.4	8.3	0.70	-0.5	3.3	14.8	1.2	16.0
4000	5.1	2.5	2.8	6.3	3.2	5.4	5.0	5.2	2.5	-1.6	4.1	7.6	0.82	0.1	3.1	14.7	1	15.7
5000	-0.1	1.7	-0.6	-0.2	-0.3	1.8	1.8	-0.5	-0.3	-3.2	0.3	4.2	1.30	-0.1	-0.9	10.6	0.5	11.1
6300	-2.1	-0.9	-2.0	0.8	-0.7	-0.4	0.4	-1.0	-2.1	-3.8	-1.0	3.1	1.30	0.2	-2.5	9.0	-0.1	8.9
8000	-4.2	-2.6	-2.8	-2.5	-2.7	-3.0	-2.1	-2.4	-2.5	-3.9	-2.8	0.8	1.30	-0.6	-3.5	8.0	-1.1	6.9
10000	-3.7	-2.6	-1.7	-0.7	-1.2	-0.7	-0.4	-1.2	-1.0	-2.7	-1.5	1.2	1.30	-0.3	-2.5	9.0	-2.5	6.5
<b>A-WEIGHTED SOUND POWER LEVEL</b>																		<b>38.5</b>

*This report is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to the units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full except with the prior written approval of the issuing laboratory.*

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 10 of 14

MEASURED TIME AVERAGED SPL at 1.5 m, L'P - [07607/14_2 - "Auto" Setting]											Mean L <sub>p</sub> over mic positions	$\Delta L_p$ [dB]	BG corr. K <sub>1</sub> , [dB]	Env corr. K <sub>2</sub> , [dB]	L <sub>p</sub> [dB]	Sound Power, L <sub>w</sub> [dB]	A- weighting corrections [dB]	Sound Power, L <sub>wA</sub> [dB]
Frequency [Hz]	Mic 1 [dB]	Mic 2 [dB]	Mic 3 [dB]	Mic 4 [dB]	Mic 5 [dB]	Mic 6 [dB]	Mic 7 [dB]	Mic 8 [dB]	Mic 9 [dB]	Mic 10 [dB]								
100	15.7	14.7	14.9	11.6	11.1	15.9	10.9	11.4	9.3	11.6	13.3	7.6	0.83	-2.0	14.4	25.9	-19.1	6.8
125	8.8	8.2	10.2	9.2	9.9	8.5	10.1	6.4	9.6	3.3	8.8	3.9	1.30	1.5	6.0	17.5	-16.1	1.4
160	6.8	6.8	8.9	6.2	7.7	6.9	6.6	4.0	4.4	-0.7	6.3	6.7	1.06	0.3	5.0	16.5	-13.4	3.1
200	14.1	13.8	16.6	13.5	15.5	13.5	15.6	10.7	12.6	5.0	13.9	20.3	0.00	-0.1	14.0	25.5	-10.9	14.6
250	12.5	10.0	13.6	11.3	13.7	9.9	10.7	7.8	8.4	6.0	11.0	19.1	0.00	1.1	9.8	21.4	-8.6	12.8
315	10.4	10.5	14.1	11.1	13.4	10.1	10.4	10.7	8.9	9.5	11.2	19.5	0.00	0.6	10.6	22.1	-6.6	15.5
400	13.4	13.3	17.0	14.4	14.7	13.9	14.0	13.5	13.7	11.7	14.2	23.6	0.00	0.5	13.7	25.2	-4.8	20.4
500	17.9	16.8	21.2	18.2	19.1	17.2	17.5	16.9	17.2	16.8	18.1	27.4	0.00	0.5	17.6	29.1	-3.2	25.9
630	23.2	20.6	25.6	21.6	22.8	19.5	20.2	20.2	18.9	19.0	21.7	30.8	0.00	0.6	21.1	32.6	-1.9	30.7
800	25.6	26.9	28.6	20.9	26.3	23.0	22.3	22.5	22.5	23.9	24.9	33.5	0.00	0.7	24.2	35.7	-0.8	34.9
1000	22.7	21.6	23.5	19.1	20.8	18.3	16.0	16.8	17.1	16.0	20.0	27.9	0.00	0.6	19.5	31.0	0	31.0
1250	18.1	17.1	14.2	14.9	15.1	15.0	12.9	12.8	12.9	12.4	14.9	22.2	0.00	0.5	14.4	25.9	0.6	26.5
1600	11.2	12.6	15.0	18.4	9.8	15.1	13.0	11.8	11.0	11.3	13.7	20.3	0.00	0.6	13.2	24.7	1	25.7
2000	13.5	10.4	12.1	13.8	8.5	10.4	13.1	9.9	10.1	8.3	11.4	17.1	0.00	0.9	10.5	22.0	1.2	23.2
2500	10.9	7.0	8.8	8.5	5.3	8.5	8.4	8.6	6.1	13.6	9.2	14.6	0.15	-1.4	10.5	22.0	1.3	23.3
3150	3.5	2.4	5.9	4.5	4.1	3.7	4.1	3.7	1.6	3.9	3.9	8.7	0.63	-0.5	3.8	15.3	1.2	16.5
4000	5.7	2.5	3.0	6.9	3.2	5.7	5.4	5.6	2.8	5.3	4.9	8.4	0.68	0.1	4.1	15.6	1	16.6
5000	-0.3	1.4	-0.6	-0.4	-0.4	1.4	1.7	-0.3	-0.6	-0.6	0.2	4.2	1.30	-0.1	-0.9	10.6	0.5	11.1
6300	-2.1	-0.7	-0.6	0.8	-0.9	-0.5	1.0	0.6	-1.1	6.6	1.1	5.2	1.30	0.2	-0.4	11.1	-0.1	11.0
8000	-3.1	-1.7	0.5	-1.1	-1.8	-1.9	0.2	-1.1	-1.3	2.9	-0.5	3.1	1.30	-0.6	-1.2	10.3	-1.1	9.2
10000	-2.2	-1.9	-1.2	0.6	0.4	0.0	0.4	-0.4	0.5	6.5	1.1	3.8	1.30	-0.3	0.1	11.6	-2.5	9.1
<b>A-WEIGHTED SOUND POWER LEVEL</b>																		<b>38.7</b>

*This report is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to the units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full except with the prior written approval of the issuing laboratory.*

# Test Report

Issued by University of Salford (Acoustics Test Laboratory)

Date of Issue: 5<sup>th</sup> March 2026

Report Number: 07607/14

Page 11 of 14

## Appendix 3 – Measured time averaged sound pressure level of RSS, $L'_{P(RSS)}$ at each microphone position

Frequency	Mic 1	Mic 2	Mic 3	Mic 4	Mic 5	Mic 6	Mic 7	Mic 8	Mic 9	Mic 10	Average $L'_{P(RSS)}$ over microphone positions	Calculated Sound Power of RSS
[Hz]	[dB]	[dB]	[dB]									
100	64.3	61.5	63.0	61.9	62.5	63.1	61.5	63.0	61.4	57.0	62.2	73.7
125	66.6	65.9	65.0	66.5	65.1	67.3	63.4	65.3	65.6	57.8	65.4	76.9
160	65.9	66.2	65.5	65.1	64.4	67.6	62.7	63.1	63.9	57.5	64.8	76.3
200	67.0	65.4	65.4	65.0	64.0	65.4	63.3	63.1	63.1	58.7	64.5	76.0
250	68.1	66.7	66.9	67.2	67.2	65.2	63.1	61.9	63.7	59.2	65.6	77.1
315	67.1	68.0	67.9	66.1	66.6	65.3	61.3	62.3	61.5	62.4	65.5	77.0
400	67.8	68.4	68.2	65.3	64.7	65.2	61.0	60.9	61.1	60.6	65.3	76.8
500	68.9	68.5	68.7	64.5	64.8	64.6	60.8	60.6	60.8	62.0	65.6	77.1
630	69.4	69.1	69.3	63.4	63.6	63.2	63.2	63.0	63.0	65.8	66.2	77.7
800	69.9	70.4	70.8	62.7	62.4	62.1	67.4	67.2	67.1	69.0	67.9	79.4
1000	70.9	70.3	71.0	63.0	62.9	62.4	69.8	69.8	69.9	66.9	68.8	80.3
1250	70.9	71.0	71.1	70.4	70.1	69.6	69.9	69.8	69.7	71.5	70.4	81.9
1600	68.5	69.0	69.5	73.2	73.2	72.6	68.8	68.7	69.1	69.7	70.7	82.2
2000	68.3	68.8	69.0	72.2	72.1	71.6	71.3	70.9	71.4	67.2	70.6	82.1
2500	63.4	63.9	64.4	67.2	67.1	66.7	68.1	68.0	68.2	64.9	66.5	78.0
3150	65.4	63.7	63.7	70.1	69.6	68.9	66.8	66.8	67.2	62.8	67.2	78.7
4000	66.8	66.5	66.7	70.2	69.6	68.9	66.6	66.7	67.0	63.3	67.6	79.1
5000	69.1	67.9	68.7	66.2	66.7	66.9	65.4	65.3	65.9	60.3	66.8	78.3
6300	68.3	67.4	68.6	65.9	66.2	66.2	64.0	63.4	64.0	59.4	66.0	77.5
8000	64.7	63.3	64.5	64.8	64.0	63.9	63.3	62.0	63.2	57.2	63.5	75.0
10000	63.0	61.3	62.9	62.9	62.6	62.7	61.4	59.9	61.6	55.9	61.8	73.3

*This report is issued in accordance with the laboratory accreditation requirements of the United Kingdom Accreditation Service. It provides traceability of measurement to recognised national standards, and to the units of measurement realised at the National Physical Laboratory or other recognised national standards laboratories. This certificate may not be reproduced other than in full except with the prior written approval of the issuing laboratory.*